

TEST REPORT



KERI



한국전기연구원
KOREA ELECTROTECHNOLOGY
RESEARCH INSTITUTE



CLASSIFICATION	Performance Test(III)
APPARATUS	Ground system
DESIGNATION	ECA 3G-CM
RATINGS	1Ø AC (100 ~ 440) V, (30 ~ 90) MJ
APPLIED STANDARD	IEC 61000-4-5(2005.11) and client's specification
RECEIPT No.	TRD06S02110 (September 20, 2006)
APPLICANT	Ground Co., Ltd. #209, Suntech City2, 307-2, Sangdaewon-dong, Jungwon-gu, Sungnam-si, Gyunggi-do, Korea
MANUFACTURER	Ground Co., Ltd. #209, Suntech City2, 307-2, Sangdaewon-dong, Jungwon-gu, Sungnam-si, Gyunggi-do, Korea
DATE OF TESTS	February 05, 2007
DATE OF ISSUE	February 12, 2007

The test results are presented in the records of tests with the performance of the tested apparatus and the observations made during the tests. The oscillograms are attached hereto.

The test results apply only to the tested specific samples.

This document shall not be reproduced except in full, without a written approval of KERI.

No. OF PAGES records (3), photographs (1), circuit diagrams (1), oscillograms (1),
INCORPORATED drawings & descriptions (0), attachments (2)

Test results in this report are within the scopes accredited by Korea Laboratory Accreditation Scheme, which signed the International Laboratory Accreditation Cooperation Mutual Recognition Arrangement

Prepared by

Kim, Jong-Hyung

Verified by

Kim, Oun-Seok

Approved by
(Technical m

Park. Byung-Rak



Power Apparatus Testing & Evaluation Division

KERI

KOREA ELECTROTECHNOLOGY RESEARCH INSTITUTE
NaeSon 2-dong 665,Uiwang-si, Gyeonggi-do, Korea, 437-808
Tel : +82-31-420-6114, Fax : +82-31-420-6029, www.keri.re.kr
KERI Laboratories are accredited by KOLAS (Korea Laboratory Accreditation Service)

Table of contents

Items	Sheet No.
Table of contents	2/3
Ratings of the test object assigned by manufacturer and proved by tests	2/3
List of tests	2/3
Test results	3/3
Photos	-

Tested by :

KERI

Kim, Jong-Hyung

Witnessed by :



Photos :

Photo DT 01 Tested apparatus

Ratings : given by test applicant

Ground system

Applied standard

IEC 61000-4-5(2005.11) and client's specification

Manufacturer

Ground Co. Ltd.

Designation

ECA 3G-CM

Ratings

1Ø AC (100 ~ 440) V, (30 ~ 90) MJ

List of tests :

Description of tests	Standard and clause	Sheet No.
1 Combination wave surge test	IEC 61000-4-5, Clause 7	3/3
2 Review of test results	-	3/3


1 Surge test

Test method and requirement	Test point	Result
<ul style="list-style-type: none">o Test specification<ul style="list-style-type: none">- Open-circuit voltage waveform of the surge generator : $1.2 \times 50 \mu\text{s}$- Short-circuit current waveform of the surge generator : $8 \times 20 \mu\text{s}$- Effective output impedance of the surge generator : 2Ω- Test level : 6 kV- Polarity : positive and negative- Repeat : 3 times each- Repetition rate : 1 per minute	Line - Line	Good
<ul style="list-style-type: none">o Requirements<ul style="list-style-type: none">- During the test, there shall be no problems of flaming, glowing, melting, etc.	Line - Earth	Good
	Earth - Ground	Good

* Test point : Refer to Fig. DT 01

2 Review of test results

2.1 This test report is the results carried out in accordance with IEC 61000-4-5(2005.11) and client's specification for the specimen given by test applicant. The end.



KERI

Photos



Tested apparatus


Calibration waveforms



Open circuit voltage waveform (1.2×50 μ s, 6 kV)





100 A / 1 V



100 A / 1 V

Short circuit current waveform (8×20 μ s, 3 kA)



Circuit diagram




- | | | | | | |
|----------|----------|--------|--------|----------|----------|
| ① Line 1 | ① Ground | Ground | Ground | ① Ground | ① Ground |
| ② Line 2 | ② Ground | | | ② Ground | ② Ground |
| ③ Earth | ③ Ground | | | ③ Ground | ③ Ground |
| | ④ Ground | | | ④ Ground | ④ Ground |

Configuration of Inner circuit and external terminals


Measured voltage waveforms at each terminal



Line 1 – Line 2




Line 1 – Earth





Line 2 – Earth



Measured voltage waveforms at each terminal



Earth – Ground



Line 1 – Ground



Line 2 – Ground

TEST REPORT



KERI



한국전기연구원
KOREA ELECTROTECHNOLOGY
RESEARCH INSTITUTE



TEST REPORT

2007TS00189 1/3

CLASSIFICATION	Performance Test(III)
APPARATUS	Ground system
DESIGNATION	ECA 3G-EM
RATINGS	1Ø AC (100 ~ 440) V, (30 ~ 90) MJ
APPLIED STANDARD	IEC 61000-4-5(2005.11) and client's specification
RECEIPT No.	TRD06S02111 (September 20, 2006)
APPLICANT	Ground Co., Ltd. #209, Suntech City2, 307-2, Sangdaewon-dong, Jungwon-gu, Sungnam-si, Gyeonggi-do, Korea
MANUFACTURER	Ground Co., Ltd. #209, Suntech City2, 307-2, Sangdaewon-dong, Jungwon-gu, Sungnam-si, Gyeonggi-do, Korea
DATE OF TESTS	February 02, 2007 ~ February 05, 2007
DATE OF ISSUE	February 12, 2007

The test results are presented in the records of tests with the performance of the tested apparatus and the observations made during the tests. The oscillograms are attached

The test results apply only to the tested specific samples.

This document shall not be reproduced except in full, without a written approval of KEPRI.

No. OF PAGES INCORPORATED records (3), photographs (1), circuit diagrams (1), oscilloscopes (1), drawings & descriptions (0). attachments (2)

Test results in this report are within the scopes accredited by Korea Laboratory Accreditation Scheme, which signed the International Laboratory Accreditation Cooperation Mutual Recognition Arrangement

Prepared by

Kim, Jong-Hyung

Verified by

Kim Oun Seok
Kim, Oun-Seok

Approved by
(Technical manager)

Park, Byung-Rak



Power Apparatus Testing & Evaluation Division

KERI

KOREA ELECTROTECHNOLOGY RESEARCH INSTITUTE
NaeSon 2-dong 665, Uiwang-si, Gyeonggi-do, Korea, 437-808
Tel : +82-31-420-6114, Fax : +82-31-420-6029, www.keri.re.kr
KERI Laboratories are accredited by KOLAS (Korea Laboratory Accreditation Scheme)

DF-E-21/14/02

Table of contents

Items	Sheet No.
Table of contents	2/3
Ratings of the test object assigned by manufacturer and proved by tests	2/3
List of tests	2/3
Test results	3/3
Photos	-

Tested by :

KERI

Kim, Jong-Hyung

Witnessed by :



Photos :

Photo DT 01 Tested apparatus

Ratings : given by test applicant

Ground system

Applied standard	IEC 61000-4-5(2005.11) and client's specification
Manufacturer	Ground Co. Ltd.
Designation	ECA 3G-EM
Ratings	1Ø AC (100 ~ 440) V, (30 ~ 90) MJ



List of tests :

Description of tests	Standard and clause	Sheet No.
1 Combination wave surge test	IEC 61000-4-5, Clause 7	3/3
2 Review of test results	-	3/3

1 Surge test

Test method and requirement	Test point	Result
<ul style="list-style-type: none">o Test specification<ul style="list-style-type: none">- Open-circuit voltage waveform of the surge generator : $1.2 \times 50 \mu s$- Short-circuit current waveform of the surge generator : $8 \times 20 \mu s$- Effective output impedance of the surge generator : 2Ω- Test level : 6 kV- Polarity : positive and negative- Repeat : 3 times each- Repetition rate : 1 per minute	Line - Line	Good
<ul style="list-style-type: none">o Requirements<ul style="list-style-type: none">- During the test, there shall be no problems of flaming, glowing, melting, etc.	Line - Earth	Good
	Earth - Ground	Good

* Test point : Refer to Fig. DT 01

2 Review of test results

2.1 This test report is the results carried out in accordance with IEC 61000-4-5(2005.11) and client's specification for the specimen given by test applicant. The end.



The KERI logo consists of the letters "KERI" in a bold, sans-serif font. The letters are partially overlaid by a large, stylized green leaf graphic that wraps around the letters, symbolizing environmental or energy research.

Photos




Tested apparatus


Calibration waveforms



Open circuit voltage waveform (1.2×50 μ s, 6 kV)




100 A / 1 V



100 A / 1 V

Short circuit current waveform (8×20 μ s, 3 kA)



Circuit diagram




- | | | | | | |
|----------|----------|--------|--------|----------|----------|
| ① Line 1 | ① Ground | Ground | Ground | ① Ground | ① Ground |
| ② Line 2 | ② Ground | | | ② Ground | ② Ground |
| ③ Earth | ③ Ground | | | ③ Ground | ③ Ground |
| | ④ Ground | | | ④ Ground | ④ Ground |

Configuration of Inner circuit and external terminals



Measured voltage waveforms at each terminal



Line 1 – Line 2





Line 1 – Earth





Line 2 – Earth



Measured voltage waveforms at each terminal



Earth - Ground



Line 1 - Ground



Line 2 - Ground

TEST REPORT



KERI



한국전기연구원
**KOREA ELECTROTECHNOLOGY
RESEARCH INSTITUTE**



CLASSIFICATION	Performance Test(III)
APPARATUS	Ground system
DESIGNATION	ECA 3G-NM
RATINGS	1Ø AC (100 ~ 440) V, (30 ~ 90) MJ
APPLIED STANDARD	IEC 61000-4-5(2005.11) and client's specification
RECEIPT No.	TRD06S02112 (September 20, 2006)
APPLICANT	Ground Co., Ltd. #209, Suntech City2, 307-2, Sangdaewon-dong, Jungwon-gu, Sungnam-si, Gyunggi-do, Korea
MANUFACTURER	Ground Co., Ltd. #209, Suntech City2, 307-2, Sangdaewon-dong, Jungwon-gu, Sungnam-si, Gyunggi-do, Korea
DATE OF TESTS	February 02, 2007 ~ February 05, 2007
DATE OF ISSUE	February 12, 2007

The tests have been carried out in accordance with the instructions of the client.

The test results are presented in the records of tests with the performance of the tested apparatus and the observations made during the tests. The oscillograms are attached hereto.

The test results apply only to the tested specific samples.

This document shall not be reproduced except in full, without a written approval of KERI.

No. OF PAGES
INCORPORATED records (3), photographs (1), circuit diagrams (1), oscilloscopes (1), drawings & descriptions (0), attachments (2)

Test results in this report are within the scopes accredited by Korea Laboratory Accreditation Scheme, which signed the International Laboratory Accreditation Cooperation Mutual Recognition Arrangement

Prepared by

Kim, Jong-Hyung

Verified by

Kim Oun Seok
Kim, Oun-Seok

Approved by
(Technical manager)

Park, Byung-Rak



Power Apparatus Testing & Evaluation Division

KERI

KOREA ELECTROTECHNOLOGY RESEARCH INSTITUTE
NaeSon 2-dong 665,Uiwang-si,Gyeonggi-do,Korea,437-808
Tel : +82-31-420-6114, Fax : +82-31-420-6029, www.keri.re.kr
KERI Laboratories are accredited by KOLAS (Korea Laboratory Accreditation Service)

DF-E-21/14/02

Table of contents

Items	Sheet No.
Table of contents	2/3
Ratings of the test object assigned by manufacturer and proved by tests	2/3
List of tests	2/3
Test results	3/3
Photos	-

Tested by :

KERI

Kim, Jong-Hyung

Witnessed by :

Photos :

Photo DT 01 Tested apparatus

Ratings : given by test applicant

Ground system

Applied standard

IEC 61000-4-5(2005.11) and client's specification

Manufacturer

Ground Co. Ltd.

Designation

ECA 3G-NM

Ratings

1Ø AC (100 ~ 440) V, (30 ~ 90) MJ

List of tests :

Description of tests	Standard and clause	Sheet No.
1 Combination wave surge test	IEC 61000-4-5, Clause 7	3/3
2 Review of test results	-	3/3


1 Surge test

Test method and requirement	Test point	Result
<ul style="list-style-type: none">o Test specification<ul style="list-style-type: none">- Open-circuit voltage waveform of the surge generator : $1.2 \times 50 \mu\text{s}$- Short-circuit current waveform of the surge generator : $8 \times 20 \mu\text{s}$- Effective output impedance of the surge generator : 2Ω- Test level : 6 kV- Polarity : positive and negative- Repeat : 3 times each- Repetition rate : 1 per minute	Line - Line	Good
<ul style="list-style-type: none">o Requirements<ul style="list-style-type: none">- During the test, there shall be no problems of flaming, glowing, melting, etc.	Line - Earth	Good
	Earth - Ground	Good

* Test point : Refer to Fig. DT 01

2 Review of test results

2.1 This test report is the results carried out in accordance with IEC 61000-4-5(2005.11) and client's specification for the specimen given by test applicant. The end.




KERI

Photos




Tested apparatus


Calibration waveforms



Open circuit voltage waveform (1.2×50 μ s, 6 kV)




100 A / 1 V



100 A / 1 V

Short circuit current waveform (8×20 μ s, 3 kA)



Circuit diagram





- | | | | | | |
|----------|----------|--------|--------|----------|----------|
| ① Line 1 | ① Ground | Ground | Ground | ① Ground | ① Ground |
| ② Line 2 | ② Ground | | | ② Ground | ② Ground |
| ③ Earth | ③ Ground | | | ③ Ground | ③ Ground |
| | ④ Ground | | | ④ Ground | ④ Ground |

Configuration of Inner circuit and external terminals



Measured voltage waveforms at each terminal



Line 1 – Line 2




Line 1 – Earth





Line 2 – Earth



Measured voltage waveforms at each terminal



Earth – Ground



Line 1 – Ground



Line 2 – Ground

TEST REPORT



KERI

 **한국전기연구원**
KOREA ELECTROTECHNOLOGY
RESEARCH INSTITUTE



시험성적서

2006TS01997

1/3

시험종류 성능확인시험

"한국전기연구원의 확인이
없는 사본은 무효임"

제품명 접지장치

형식명 ECA 3G-LM

정격 1Ø AC (100 ~ 440) V, (30 ~ 90) MJ

적용규격 시험의뢰자 시방

접수번호 TRD06S02109(2006.09.20)

의뢰자 (주)그라운드
경기도 성남시 중원구 상대원동 307-2 선택시티투아파트형공장 209제작자 (주)그라운드
경기도 성남시 중원구 상대원동 307-2 선택시티투아파트형공장 209

시험일자 2006.10.20

발행일자 2006.11.07

시험결과

참고시험으로써 서지제한전압측정시험 및 접지전류측정시험을 실시한 결과 첨부와 같음

시험결과는 시험을 실시한 제품에만 해당됨

KERI의 서면승인 없이 시험성적서의 일부만을 복사하여 사용할 수 없음

시험성적서 구성페이지 ; 성적서 (3), 사진 (1), 회로도 (1), Oscillograms (3),
도면 (0), 첨부 (0)

위 성적서는 국제시험소인정협력체(International Laboratory Accreditation Cooperation)
상호인정협정(Mutual Recognition Arrangement)에 서명한 한국교정시험기관인정기구(KOLAS)로부터 공인받
은 분야에 대한 시험결과입니다.



한국전기연구원장

승인
(기술책임자) 박병락

확인 김언석

작성 김종형

**KERI**

한국전기연구원 Korea Electrotechnology Research Institute

437-808, 경기도 의왕시 내순2동 665

Tel : +82-31-420-6114, Fax : +82-31-420-6029, www.keri.re.kr

공인시험기관 - KOLAS (한국교정시험기관인정기구) 인정

DF-E-21/11/02

목차

항 목	페이지 번호
목차	2/3
정격	2/3
시험목록	2/3
시험항목결과	3/3
사진	-

시험자 :

한국전기연구원

김종형

입회자 :

(주)그라운드

우제욱

사진 :

Photo DT 01

피시품 및 접지전류측정시험

정격 : 시험의뢰자 제시

접지장치

적용규격

시험의뢰자 시방

형식명

ECA 3G-LM

정격

1Ø AC (100 ~ 440) V, (30 ~ 90) MJ

시험목록**시험항목**

- 1 서지제한전압측정시험
- 2 접지전류측정시험
- 3 시험결과검토

시험회로도**페이지 번호**

-	3/3
-	3/3
-	3/3

1 서지제한전압측정시험

시험방법	인가 및 측정지점	측정결과(kV)	
		1회	1.83
○ 시험방법	Line 1 - Line 2	2회	1.81
		3회	1.83
		4회	1.82
		5회	1.80
		1회	1.97
○ 측정	Line 1 - Earth	2회	1.99
		3회	2.00
		4회	1.97
		5회	1.97
		1회	1.33
○ 측정	Line 2 - Earth	2회	1.32
		3회	1.34
		4회	1.33
		5회	1.32
		1회	1.33

* 인가 및 측정지점 : Fig. DT 01 참조

* 측정결과 : Osc. DT 02 참조

2 접지전류측정시험

시험방법	측정결과(A)	
○ 시험방법	1회	108
- 서지발생기 개방회로전압 : $1.2 \times 50 \mu s$, 6 kV - 서지발생기 단락회로전류 : $8 \times 20 \mu s$, 3 kA - 서지발생기 유효출력임피던스 : 2 Ω - 서지인가지점 : 피시품의 Ground 단자와 Earth 단자 간 - 전류측정지점 : Earth 리드선 - 서지인가횟수 및 간격 : 정극성 3회, 60 s	2회	107
○ 측정	3회	108
- 상기 조합서지를 인가했을 때 Earth 단자로 흐르는 전류를 측정		


* 인가 및 측정지점 : Fig. DT 01 참조

* 측정결과 : Osc. DT 03 참조


3 시험결과검토

- 3.1 상기 시험성적은 의뢰자가 제출한 피시품에 대하여 시험의뢰자 시방에 의거 시험한 결과임
- 3.2 접지전류측정시험은 외부단자(Fig. DT 01 참조) 중 우측 2번째 Ground의 4번 단자와 Earth 단자에 대해 실시한 결과임 끝.

조합 서지 calibration 과정



개방회로전압(1.2×50 µs, 6 kV)




단락회로전류(8×20 µs, 3 kA)

서지제 한전압측정



Line 1 - Line 2




Line 1 - Earth




Line 2 - Earth

접지전류측정



회로도



(1) Line 1

(2) Line 2

(3) Earth

(1) Ground

(2) Ground

(3) Ground

(4) Ground

Ground

Ground

(1) Ground

(2) Ground

(3) Ground

(4) Ground

(1) Ground

(2) Ground

(3) Ground

(4) Ground

피시품 내부회로 및 외부단자